GOVERNMENT OF ARUNACHAL PRADESH
OFFICE OF THE ASSISTANT ENGINEER PHE & WS SUB-DIVISION,
BANA ::: 790102

No. AE/PHE/ESTT-03/2025-26/ 22-23 **Dated : 1/10/2026**

SAFE DRINKING WATER AND SANITATION CERTIFICATE

It is to certify that an inspection team headed by **Er. Mayan Kino,** Assistant Engineer from PHE & WS Department inspected the **Govt. Secondary School, Lumdung** on 28th September'2026 and on the basis of Water Test Report attached bearing No. EE/PHE/WQ/Lab-03/2025-26/22-23 Dated 29/09/2026 of **DISTRICT WATER QUALITY TESTING LABORATORY.**

Certified that the **Govt. Secondary School, Lumdung** has safe drinking water facilities for the students and members of staff of the institution, School also maintains the hygiene sanitation condition in the building and the campus as per norms prescribed by the State Govt.

This certificate is valid up to 6(six) month from the date of issue.

01/x/2026

(Er. Mayan Kino)
Assistant Engineer
PHE & WS Sub-Division, Bana

Assistant Engineer
PHE&WS Sub-Division
Bana

To,

The Principal/Head Master
Govt. Secondary School, Lumdung

GOVERNMENT OF ARUNACHAL PRADESH
OFFICE OF THE EXECUTIVE ENGINEER PHE & WS DIVISION, SEPPA
(DISTRICT WATER QUAITY TESTING LABORATORY)

No. EES/PHE/WQ/Lab-03/2025-26/22-23 Dated : 01/10/2026

Name of Block : Bana
Name of School : Govt. Secondary School Lumdung
Name of Source : Romebung
Date of sample collection : 28/09/2026
Date of Testing : 29/09/2026

WATER ANALYSIS REPORT

PHYSICAL AND CHEMICAL PARAMETERS

Sl. No.	Parameter (Unit)	Accepteble Limit (BIS)	Permissible Limit (BIS)	Result
1	Turbidity (NTU)	1	5	2.84
2	pH	6.5-8.5	No rexation	7.23
3	Total Hardness as CaCO3 (mg/l)	200	600	25
4	Total Alkalinity (mg/l)	200	600	46
5	Chlorides as Cl (mg/l)	250	1000	30
6	Fluorides as F (mg/l)	1	1.5	0.125
7	Iron as Fe (mg/l)	1	No rexation	0.26
8	Thermotolerant Coliform Bacteria	0	No rexation	0
9	Total Coliform	0	No rexation	0

Lab Assistant
PHE & WS Division
Seppa

01/10/2026

Assistant Engineer
PHE & WS Sub-Division
Bana

Assistant Engineer
PHE&WS Sub-Division
Bana